

$$\frac{T_{02}}{T_{01}} = r_p^{\frac{\gamma}{\gamma-1}}$$


$$\eta_p = \frac{1}{1 - \left(\frac{\gamma-1}{\gamma}\right)(r_p - 1)}$$

$$\eta_p = \left(\frac{\gamma-1}{\gamma}\right) \left(\frac{n}{n-1}\right)$$

$$\gamma = \frac{C_p}{C_v}$$

$$\rightarrow (0.6 - 0.8) \quad (\Delta h)$$

Due to the shape of the isentropy lines, lower inlet temperatures require less energy for same Δp



polytropic head on

- Estimate required compression power $P = \frac{H_p \cdot g \cdot \dot{m}}{\eta_p \cdot \eta_m}$

2.52 m compression

in pump head $h_z = \frac{\Delta p}{\rho g}$

$$g = 9.81 \text{ m/s}^2$$

$$\eta_m = 95 - 99\%$$

$$H_p = \frac{T_{02} - T_{01}}{g} \cdot \frac{R}{n-1} \cdot \left(r_p^{\frac{n}{n-1}} - 1 \right)$$

$$z_{av} = \frac{z_m + z_{out}}{2}$$

$$R = \frac{R_u}{M_w}$$

surge line

Operation map compressor

given


usually generated with certain

gas $\rightarrow M_w, K$ (air)

$\rightarrow T_{in}, P_{in}$

$\hookrightarrow 1.01325 \text{ bar}$

$\hookrightarrow T_{amb} = 20^\circ\text{C}$



test conditions are typically not equal to actual operating conditions
therefore it is necessary to convert from test conditions to actual conditions

$$q_{new} = q_{test} \sqrt{\frac{\kappa_{new}}{\kappa_{test}}} \cdot \sqrt{\frac{MW_{test}}{MW_{new}}} \cdot \sqrt{\frac{T_{new}}{T_{test}}}$$

$$H_{pnew} = H_{ptest} \frac{\kappa_{new}}{\kappa_{test}} \frac{MW_{test}}{MW_{new}} \cdot \frac{T_{new}}{T_{test}}$$

for our case we will convert the operational point to compressor test conditions


$$H_{ptest} = H_{pnew} \frac{\kappa_{test}}{\kappa_{new}} \cdot \frac{MW_{new}}{MW_{test}} \cdot \frac{T_{test}}{T_{new}}$$

$$q_{test} = q_{new} \sqrt{\frac{\kappa_{test}}{\kappa_{new}}} \sqrt{\frac{MW_{new}}{MW_{test}}} \sqrt{\frac{T_{test}}{T_{new}}}$$


$$B_g(p, T) = \frac{q_g(p, T)}{q_g(p_{sc}, T_{sc})} \quad q_g = q_g \cdot B_g$$

$$B_g = \frac{V_g(p, T)}{V_g(p_{sc}, T_{sc})}$$

Process Flow Diagram




Process Modules- Sizes and Dry Weights



Cooler duty

$$\dot{Q} = \dot{m} (h_{inlet} - h_{outlet})$$

11 MW 67°C



<http://www.ipt.ntnu.no/>

COMPRESSION STARTS														
Deltap choke comp	p_suc	pcomp dis	Tpiem	DT inlet cooler	Tsuc	rp	deltap	np-eff	n	Tdis	DT outlet cooler	Tin_pipeline	zsuc	zdisc
[bar]	[bara]	[bara]	[C]	[C]	[C]	[-]	[bar]	[-]	[-]	[C]	[C]	[C]		
0	76.1	78.7	67	0	67	1.03	2.6	0.7	1.49	70.8	0	70.8		
0	66.8	78.7	67	0	67	1.18	11.9	0.7	1.49	85.9	0	85.9		
0	56.7	78.7	67	0	67	1.39	22.0	0.7	1.49	105.7	0	105.7		
0	45.3	78.7	67	0	67	1.74	33.4	0.7	1.49	134.8	0	134.8		
0	31.1	78.7	67	0	67	2.53	47.5	0.7	1.49	188.3	0	188.3		
0	#VALUE!	78.7	67	0	67	#VALUE!	#VALUE!	0.7	1.49	#VALUE!	0	#VALUE!		
0	#VALUE!	78.7	67	0	67	#VALUE!	#VALUE!	0.7	1.49	#VALUE!	0	#VALUE!		
0	#VALUE!	78.7	67	0	67	#VALUE!	#VALUE!	0.7	1.49	#VALUE!	0	#VALUE!		

Tsc
k
Polytropic effc
Mech. Effic

288.71 K
1.30
0.7
0.95

Pin, bara
Tin, K
Zin
Mw

50
298.15
0.98
28.97

zsuc	zdisc	Bg @suc	qg_local	Hp	m	Power	Hp test	qact test	qact test single comp
		[m^3/Sm^3]	[m^3/d]	[m]	[kg/s]	[MW]	[m]	[m^3/d]	[m^3/d]
0.928	0.930	1.46E-02	292.0E+3	565.1	155.7E+0	1.30	294.8	210883.7638	
0.935	0.942	1.68E-02	335.2E+3	2851.9	155.7E+0	6.55	1487.9	242119.9827	
0.944	0.955	1.99E-02	398.4E+3	5924.7	155.7E+0	13.61	3091.0	287755.5395	
0.954	0.970	2.52E-02	504.1E+3	10505.5	155.7E+0	24.13	5480.9	364116.1919	
0.967	0.988	3.72E-02	743.8E+3	19107.5	155.7E+0	43.89	9968.8	537247.0699	

